



# Product Specification Bulletin

175 Watt

PULSE START

**UNI-FORM**  
PULSE START SYSTEM

Coated - 4K

**Mogul - Enclosed Luminaire**



BASE UP ± 15°

## MS 175W/C/BU/PS

Product Number

68246

### Lamp Type

SINGLE ENDED METAL HALIDE

### ANSI Designation

M137, M152/E

### Performance Data

<i>Light Output (Lumens @ 100 Hrs.)</i>	16600
<i>Lamp Lumens Per Watt</i>	95
<i>Mean Output (Lumens)</i>	13300
<i>Rated Life (Hrs. @ 10 Hr. / Start)</i>	15000
<i>Correlated Color Temperature K</i>	3700
<i>Chromaticity (CIE -X, Y)</i>	.395 .390
<i>Color Rendering Index (CRI)</i>	70
<i>Typical Warm Up Time (Minutes)</i>	1-2
<i>Typical Hot Restart Time (Minutes)</i>	2-4
<i>Burning Position</i>	BASE UP ± 15°

### Physical Data / Requirements

<i>Base Designation</i>	MOGUL (E39)
<i>Bulb Designation</i>	ED28
<i>Bulb Diameter</i>	3 1/2"
<i>Max. Overall Length (MOL)</i>	8 5/16"
<i>Light Center Length (LCL)</i>	5"
<i>Effective Arc Length</i>	N/A
<i>Max. Base Temperature (°C)</i>	210
<i>Max. Bulb Temperature (°C)</i>	400
<i>Luminaire Type</i>	ENCLOSED
<i>Socket Pulse Rating (KV)</i>	4
<i>Socket Style</i>	MOGUL

### Electrical Data / Requirements

<i>Lamp Wattage</i>	175
<i>Operating Voltage (Nominal)</i>	132
<i>Operating Current (Amps)</i>	1.5
<i>Min. Open Circuit Voltage (RMS)</i>	254
<i>Min. -Max. Starting Pulse (Peak V)</i>	3000-4000
<i>Min. Pulse Width At 2700 Volts (u sec)</i>	1
<i>Min. Pulse Rate Per 1/2 Cycle</i>	1
<i>Pulse Position (Min. % OCV Peak)</i>	90

Revision: 6/5/2002

1946 - 5

### Notes

- ▶ Lamps are not warranted for rated life when operated on ballasts with less than the 270V minimum sustaining voltage (Vss) required in new ANSI specifications. Contact ballast manufacturer to find out if their CWA ballasts meet this and other specification requirements. All Venture ballasts meet these new specifications.

Lamps

THIS LAMP CONFORMS TO FEDERAL STANDARD 21 CFR 1040.30

Warning: This lamp can cause skin burn and eye inflammation from shortwave ultraviolet radiation if outer envelope of the lamp is broken or punctured. Do not use where people will remain for more than a few minutes unless adequate shielding or other safety precautions are used. Lamps that will automatically extinguish when outer envelope is broken or punctured are commercially available.